

AW Reference:
LPA Reference:

17654
Barrowden Neighbourhood Plan

RAG Key

Red	Major Constraints to Provision of infrastructure and/or treatment to serve proposed growth
Amber	Infrastructure and/or treatment upgrades required to serve proposed growth or diversion of assets may be required
Green	Capacity available to serve the proposed growth
N/A	Outside Anglian Water's boundary of water supply and / or service for sewerage treatment purposes

m - Must Complete before sending to Maps & D:				SGPE				Overall RAG rating
Site Ref	Parish		Assets Affected Comments	Water Recycling Centre (WRC)	WRC capacity	Used Water Network capacity	Used Water Comments	
Site 1	Barrowden	FALSE	No Assets	BARROWDEN WRC	Amber	Amber	May require enhancements to treatment capacity	AMBER
Site 2	Barrowden	FALSE	No Assets	BARROWDEN WRC	Amber	Green	May require enhancements to treatment capacity	AMBER
Site 3	Barrowden	FALSE	225m Foul Sewer Pipe	BARROWDEN WRC	Amber	Green	May require enhancements to treatment capacity	AMBER
Site 4	Barrowden	FALSE	No Assets	BARROWDEN WRC	Amber	Green	May require enhancements to treatment capacity	AMBER
Site 5	Barrowden	FALSE	No Assets	BARROWDEN WRC	Red	Amber	May require enhancements to treatment capacity	RED
Site 6	Barrowden	FALSE	No Assets	BARROWDEN WRC	Amber	Green	May require enhancements to treatment capacity	AMBER
Site 7	Barrowden	FALSE	No Assets	BARROWDEN WRC	Amber	Green	May require enhancements to treatment capacity	AMBER
Site 8	Barrowden	FALSE	No Assets	BARROWDEN WRC	Red	Amber	May require enhancements to treatment capacity	RED